

Superior **Equipment Co. Inc.**

2252 W. Division
Springfield, Mo. 65802
Phone (417) 865-1636

Atten: Gene Pabst
Springfield City Hall
Sanitary Service Dept.
Room 210
Springfield, Mo. 65802



Superior Equipment Co. Inc.



~~XXXXXXXXXXXX~~
2552 W. Division

• SPRINGFIELD, MO. 65802 •

PHONE (417) 865-1636

May 13, 1976

Atten: Gene Pabst
Springfield City Hall
Sanitary Service Dept.
Room 210
Springfield, Mo. 65802

Re: Peck Sinclair Service Station
400 W. Kearney
Springfield, Mo. 65803
Pressure Test underground gasoline tanks and piping.

Dear Mr. Pabst,

Mr. Peck requested us to air pressure test all underground gasoline tanks and piping at his service station at 400 W. Kearney for any possible leakage. Mr. Peck has one 8000 gallon, three 3000 gallon and one 2000 gallon storage tanks at his station. The gasoline pumps were pulled off the islands, the fill pipe and end of the vent lines were capped and 5 PSI of air pressure was put on the entire system. The product level in the tanks was checked before and after the test. There was ^{no} pressure lost on any system and there was no product lose in any tank.

The air test results indicate that no gasoline is being lost at this location.

If there are any questions please feel free to call.

Sincerely

Albert Uckele
Branch Manager

AAU/sf
CC Mr. Guy Peck

400 W. Kearney